

MCNP4C Photon Dose Calculations Compared to Measurements

Andrew Hodgdon and Jo Ann Pelczar

Duke Engineering and Services
Radiological Engineering Group
400 Donald Lynch Boulevard
Marlborough, MA 01752

978-568-2750
AndrewHodgdon@attbi.com

given ANS RPSD Santa Fe April 18, 2002

OVERALL GOAL

Re-calculate neutron and photon dose rates for PWR fuel in dry storage.

CONFIGURATIONS

- canisters
- transfer casks
- bunkers (*photons reported here*)

ISFSI

Independent Spent Fuel Storage Installation

Two PWRs

NUHOMS 24P Design

Focused on two recent canisters

Had radiation surveys

CANISTER




Figure 1.3-1

NUHOMS®-24P Dry Shielded Canister Assembly Components


SIMILAR (NAC)
CANISTER
no shell



CASK



CASK TOP SECTION




BUNKERS




LOAD SEQUENCE

1. **Canister Into
Cask**
2. **Cask Into
Spent Fuel
Pool**
3. **24 Assemblies
Loaded Into the
Canister**




LOAD SEQUENCE (cont.)

4. Cask Hoisted to Cask Pit and washed
5. Canister Dried, Welded, Surveyed
6. Cask Closed and Surveyed



LOAD SEQUENCE (cont.)


7. Cask
hoisted to
truck
8. Truck
driven to
Bunker



LOAD SEQUENCE (cont.)

9. Canister Pushed into Bunker

10. Bunker Door Shut



SOURCE POWER METHOD

ORIGEN2.1 (*historical reasons*)

Various axial burnups

Luksic flux factors for end–
fittings+ Empirical adjustments

CANISTER LOAD

10	metric tons fuel
21	assemblies
	<i>@40 GWD/MTU</i>
3	weaker
12	years decay
16	kW heat
4.2E16	photons/s
3.8E9	neutrons/s

CANISTER LOAD (cont.)

Assembly	Burnup GWD/MTU	Decay years	Enrichment % U235
1	44.6	11.7	3.40
2	43.5	11.7	4.05
3	43.4	11.7	4.05
4	43.4	11.7	4.05
5	42.7	11.7	4.05
6	40.0	12.7	4.05
7	39.9	12.7	4.05
8	39.9	12.7	4.05
9	39.9	12.7	4.05
10	39.8	12.7	4.05
11	39.4	12.7	3.40
12	39.3	12.7	4.05
13	39.1	12.7	4.05
14	38.3	12.7	4.05
15	38.2	12.7	4.05
16	38.1	12.7	3.40
17	37.6	11.7	4.05
18	36.5	12.7	4.05
19	36.4	12.7	4.05
20	36.4	12.7	4.05
21	36.4	11.7	4.05
22	31.9	16.6	3.65
23	30.5	19.9	2.99
24	27.5	21.2	2.45
ave	38.4	13.2	3.84
std err %	10	18	11

DOSE CALCULATION SUMMARY

MCNP4C – four models

Homogenized fuel

Eleven axial source regions


Basket detail

Concrete re-bar/aggregate

R0-2 energy response


BUNKER MODEL

Note
Detectors A
through G




BUNKER MODEL VIEW by MORITZ

(Ken Van Riper)



BUNKER MODEL *cross section*



RESULTS SUMMARY

Model	Description	Range C/M
1	Base Model	1.8 – 17.5
2	+basket and rebar	1.8 – 9.5
3	+axial burn-up	1.6 – 3.3
4	+Eberline RO-2 response	0.96 – 2.2

CONCLUSION

ORIGEN2.1 and MCNP4C
can achieve
C/M of 0.96 to 2.2.

CALCULATIONAL CHALLENGES

Source Nuclides

Cs137 Axial Dist.

Co60 End Fittings

Cm244 Fuel

Source Depth

70 cm (18 mfp = infinite)

Shield Depth

90 cm concrete (18 mfp)

11 cm lead (11 mfp)

Vent Streaming

3-dimensional

energy shift from 1 to 0.1 MeV

CALCULATIONAL OPTIONS

1. Parametrics (QAD and GGG)

Not made for neutrons

Not made for penetrations

2. Discrete Ordinates (DORT)

Quadrature sets require user attention

Not made for 3D

CALCULATIONAL OPTIONS

3. Monte Carlo – Detailed Geometry

Pin or Assembly detail

Not required – $1 \text{ mfp} = 4 \text{ cm}$


4. Monte Carlo – Homogenized Geometry

Measurements


Increase Detail Until Desired C/M

$C/M = \text{Calculated/Measured Ratios}$

fuel




assemblies



**MODELING
DETAIL**

pins



MCNP4C Models – Increasing Detail

Model 1 – Base Model

Model 2 – added re-bar and basket

Model 3 – added axial detail

Model 4 – added detector energy
response

MCNP MODEL 1

Three axial source regions:

Lower end fitting

Active fuel

Upper end fitting

Concrete density 2.4 g/cc

Dose rates in mrem/h (*ANSI 6.1.1.–77*)

RESULTS

$$2 < C/M < 18$$

MCNP MODEL 2

Added canister basket

Added multiple concrete regions

re-bar


empirical aggregate

$2.44 < \text{density} < 2.52 \text{ g/cc}$

RESULTS

$2 < \text{C/M} < 10$

MODEL 2 (showing re-bar)




MODEL 2

(Effect of Re-bar)

Concrete thickness (cm)	mR/h measured	C/M no rebar	C/M with rebar
61	425	3.5	1.6
91	25	3.5	1.0

MODEL 2

(Axial Sensitivity of Detectors E and G)



MODEL 3

Added Axial Source Refinement

Active Fuel – 7 Zones

Upper End Fitting

3 Zones

Luksic (PNL–6906) Flux Factors


Springs reduced 3x (empirical data)

RESULTS


$$1.6 < C/M < 3.3$$

MODEL 3

Upper End Fitting Springs




MODEL 3 Canister




MODEL 3

Axial Photon Distribution




MODEL 3

100 KeV Average at Vent



MODEL 4

Eberline RO-2 Energy Response




MODEL 4

Added Eberline RO-2 Energy Response
Rem vs Roentgen
(Calibrated within 10%)
Calculated Roentgen
Corrected from 40 to 70 Degrees F

RESULTS

$$.96 < C/M < 2.2$$


Rem =
2 x
Roentgen
at 80 KeV



PHOTON RESULTS BY MODEL

Model	Description	Range C/M
1	Base Model	1.8 – 17.5
2	+basket and rebar	1.8 – 9.5
3	+axial burn-up	1.6 – 3.3
4	+EberlineRO-2 response	0.96 – 2.2

Photon C/M by Detector and Model



% CONTRIBUTION BY PHOTON SOURCE

Detector	Lower EF	Fuel	Upper EF
A	2	96	2
B	83	16	1
C	17	82	1
D	14	84	2
E	5	83	12
F	0	69	30
G	0	67	33

Neutron C/M

<u>Location</u>	<u>C/M</u>
Top Vents	0.2 to 0.3
Contact Bottom DSC	0.7 to 0.8
Through 2 Ft Concrete	1.6

CONCLUSIONS

ORIGEN2.1 and MCNP4C can model photons from bunkered fuel within factor of two. We achieved this with:

- iteration against measurements
- homogenized assemblies
- eleven axial source zones
- end-fitting data beyond Luksic
- basket and discs
- multiple re-bar zones
- aggregate detail for concrete
- exposure energy response for detectors

NEXT TIME

Accelerate – Some runs took 3000 minutes

- Partition at Canister Surface

- Run Sources Separately

Balance Model

- Better Cell Splitting

- More regions in fuel

- Weight Windows

ORIGEN–S (more accurate energies and transuranics)

Characterize Co–60 by Measurement in Fuel Pool

Fuel Placement

MCNP4C Photon Dose Calculations Compared to Measurements

Andrew Hodgdon and Jo Ann Pelczar

Duke Engineering and Services
Radiological Engineering Group
400 Donald Lynch Boulevard
Marlborough, MA 01752

978-568-2750
AndrewHodgdon@attbi.com

given ANS RPSD Santa Fe April 18, 2002