

Building: _____

Date: _____

Room: _____

**MIT HOUSING DEPARTMENT
FIRE SAFETY ROOM INSPECTION REPORT**

Dormitory: Suites, Bedrooms, Bathrooms, Livingrooms

Please correct the follow safety hazards found during this inspection:

- Illegal Electrical Appliances/Devices**
Please Remove: _____
- Overloaded Electrical Receptacles**
- Refrigerator:**
MUST be plugged directly into outlet or a heavy- duty extension cord.
- Improper Flammable and Combustible Liquid Storage**
- Remove Candles and/or Oil Lamps**
- Excessive Combustible Items on (circle): Walls/ Ceilings/ Doors/ Floor**
(Combustible Materials Include: Wall Hangings, Tapestries, Flags)
(Must cover no more than 1/3 of available space)
- Bed Too Close to Ceiling**
(Required to have 36 inches between top of mattress and the ceiling or sprinkler head)
- Obstructed Fire Protection Equipment**
Please Remove _____ from _____
- Furniture Directly Against Room Heating Elements/Electrical Service**
(Air Gap Must be Maintained Around Electrical Wiring/Heating Elements)
- Hazardous Materials**
Please remove: _____
- Obstructed Egresses**
- Furniture Inventory**
- Smoke Detector Test**
- Please Remove all Halogen Lamps without Grate**
- Other:** _____

Inspector's Signature: _____