

G. Becerra, E. Esparza, A. Finan,  
E. Helvenston, S. Hembrador,  
K. Hohnholt, T. Khan,  
D. Legault, M. Lyttle,  
K. Miu, C. Murray,  
N. Parmar, S. Sheppard,  
C. Sizer, L. Zakszewski, K. Zeller

Friday December 9<sup>th</sup>, 2005

# Integration of Nuclear Power with Canadian Oil Sands

# Purpose

- To analyze the feasibility of integrating a nuclear power plant with Steam-Assisted Gravity Drainage (SAGD), an oil extraction technology currently used in Canadian oil sands projects



# Outline

- Canadian Oil Sands
- Extraction Methods
- Natural Gas Usage
- Energy Requirements
- Nuclear Plant Designs
- Economics
- Nuclear Reactor Licensing
- Nuclear Waste Management
- Obstacles to Nuclear
- Opportunities
- Conclusion
- Questions




# Canadian Oil Sands




# Canadian Oil Sands


- Composition—oil in the form of bitumen
- Proven reserves in Canada contain 178 billion barrels
- Satisfies Canadian crude oil demand for for over 200 years




# Recoverable Oil Reserves



# Canadian Oil Forecast



# U.S. Oil Production






# Extraction Methods



# Surface Mining




# Surface Mining Process



→ Diluted bitumen to upgrader




# In-situ SAGD




# Resources

- Surface mining dominant oil sands industry today
- ~80% of the deposits in Canada are too deep for surface mining





# Mining/In-situ Production Forecast



# Surface Mining

## *Pros*

- High established production rates
- Field lifetime of about 30 years

## *Cons*

- Higher environmental impact
- 80% of bitumen too deep for surface mining
- Production to level off around 2020

# SAGD

## *Pros*


- Phased project designs
- Some planned production rates at 100,000 Bbl/day

## *Cons*

- Demands more natural gas
- Limitations on piping steam
- Well lifetimes are 10-15 years, but phased projects can last >25 years




# Reference Plant







# Natural Gas Usage in Oil Sands Facilities




# Natural Gas Usage in Oil Sands Facilities





# Natural Gas Requirements (In mmcf/100,000 bbl)






# Historical Trend of Natural Gas Prices



## Greenhouse Gas Emissions from Oil Sands Facilities

- Greenhouse gases:  $\text{NO}_2$  &  $\text{NO}$ ,  $\text{SO}_2$ ,  $\text{CO}_2$
- 2002: ~20 Mt  $\text{CO}_2$ /year, 2012 ~100 Mt  $\text{CO}_2$ /year
- Making oil from oil sands produces 3x more greenhouse gases than producing conventional oil



# Kyoto Protocol

- Canada agrees to reduce greenhouse gas emissions by 6% relative to the 1990 level of 612 Mt by 2008-2012 to 575Mt
- Canada's Climate Change Plan (2002/2005)
  - Would like to reduce emissions to 305 Mt
  - In 2012 (at 100Mt CO<sub>2</sub>) 17% of total Kyoto target (575 Mt), 29% of Climate Change Plan target (305 Mt)



# Natural Gas Usage Conclusions

- Price of natural gas is increasing, due to decreasing supply and increasing demand
- The desire to decrease emissions in Canada
- Must look for another source of energy to fuel oil sands facilities





# Energy Requirements



## Scenario One:

- Production – SAGD Process Heat Only
- Electricity from off-site source
- Product – Diluted bitumen

## Scenario Two:

- Production – SAGD Process Heat and Electricity for on-site needs
- Product – Diluted bitumen


## Scenario Three:

- Production – SAGD Process Heat, Electricity for on-site needs, and Hydrogen for upgrading needs
- SynCrude



# Scenario One: Process Heat Only

- 100,000 bbl/day



	2 MPa	6 MPa
Low performance	1,230 MW <sub>th</sub>	1,264 MW <sub>th</sub>
High performance	820 MW <sub>th</sub>	843 MW <sub>th</sub>




## **Second Scenario: Process Heat and Electricity**


- In addition to SAGD process heat requirements, 250 MWe is required for the on-site requirements of a 100,000 bbl/day facility
- Total needs for electricity and process heat will be 1,400 to 1,600 MWth



# Reactor/Steam Generator Configurations for Scenario 2



Split Flow



In Series




# Scenario Three: Process Heat, Electricity, and Hydrogen

- Process heat and electricity requirements remain the same
- A further 100 MWe will be needed to supply the upgrading facility
- High Temperature Steam Electrolysis was chosen as the hydrogen production method
- When on-site upgrading is performed, an additional 310 MWe and 80 MWth will be required for hydrogen production
- Total needs for electricity and process heat will be 2,495 to 2,800 MWth




# Reactor/Steam Generator Configuration for Scenario Three

- Two possible reactor/steam generator configurations
- Split flow system is ideal as it allows a low temperature reactor to be used if desired



Partially Split Flow



Split Flow




# Nuclear Reactor Design Options






## ACR-700

- Thermal Power: 1983MWth
- Electrical Power: 731MWe
- Primary coolant: Light Water
- Moderator: Heavy Water
- Primary Outlet: 326°C
- Fuel: Canflex bundle; SEU (slightly enriched Uranium) ~2%
- Most accepted in Canada because it is Canadian technology




## PBMR(1 unit)

- Thermal Power: 400MWth
- Electrical Power: 165MWe
- Primary coolant: Helium
- Moderator: Graphite
- Primary outlet: 900°C
- Fuel Pebbles: 60mm, outer dia., encloses ~11,000 C/SiC coated fuel microspheres of  $\text{UO}_2$
- May be difficult to license; it has many technological innovations




## AP600

- Thermal Power: 1940MWth
- Electric Power: 600MWe
- Primary Coolant and Moderator:  
Light Water
- Primary Outlet: 316°C
- Fuel: 4.20 wt %  $^{235}\text{U}$ ,  
sometimes MOX  
(mixed oxide) fuel
- Prides its passive safety,  
USNRC completed final design  
approval, but Canadians are  
still relatively unfamiliar with  
PWRs




# Optimal reactors for Scenario One

- A reactor needs to be able to provide up to 1,264 MWth at peak load
- Either one AP600 or four PBMRs would meet this energy requirement



# Optimal Reactors for Scenario Two


- A reactor needs to provide up to 1400 - 1600 MWth at peak
- One ACR-700 could be used by modifying its conventional configuration
- Configuration could also use the split flow from five PBMRs in parallel






# Dedicated Reactors

- Alternatively process heat and electricity can also be provided with dedicated reactors to meet each requirement



Process Heat Plant  
(3 PBMR Units)




Electricity Generation Plant  
(2 PBMR Units)




# Optimal Reactors for Scenario Three

- Either two ACR-700s or two AP600s in parallel would be acceptable for this scenario
- Configuration could use the split flow from eight PBMRs in parallel




# Dedicated Reactors

- Alternatively, process heat and electricity can also be provided with dedicated reactors to meet each requirement



Process Heat Plant  
(3 PBMR Units)




Electricity Generation Plant  
(5 PBMR Units)





# Economics



# Purpose of economic analysis

1. Should natural gas or nuclear be used for the SAGD extraction process?
2. Should the electricity requirements of the plant be fulfilled by buying electricity off the power grids, or by making it at the plant?
3. Should the hydrogen required for the bitumen upgrading process be bought from private suppliers, or produced at the plant?



# Economic Assumptions

- All costs are in US dollars (US\$)
- The lifetime for the plants are assumed to be 30 years, and the Net Present Value (NPV) is calculated for a 10% discount rate
- No inflation is assumed
- Easy access to Alberta electricity power grid is assumed, price is ~US\$0.05/kWhr
- Buying price of hydrogen is assumed to be ~US\$2.50/kg of H<sub>2</sub>
- Costs do not include that of processing and upgrading plants as these are held constant and independent of heat source used
- 4 categories of cost: capital, O&M, fuel and decommissioning
- 3 final types of costs looked at: Cost of Process Heat, Cost of Electricity, and Cost of Hydrogen Production



# Additional Natural Gas-specific Assumptions

- Natural gas price is assumed to be \$8.00/mmBtu
- Kyoto protocol costs were not included in the calculations and would have resulted in an increase in the total cost for natural gas plants since they produce large quantities of CO<sub>2</sub>
- No natural gas price escalation over time is assumed




# Natural Gas Lifetime Cost


Type of Cost	Lifetime Cost (\$M over 30 years)		
	Scenario 1	Scenario 2	Scenario 3
Process Heat	2976.9	2976.9	2976.9
Electricity	1053	1178.4	1178.4
Hydrogen	-	-	Buy - 2744.2
			Make - 1920.3
<b><i>Total</i></b>	<b><i>4029.9</i></b>	<b><i>4155.3</i></b>	<b><i>6075.6</i></b>



# Volatility of Natural Gas Price and Effect on Gas-Fired Facilities



## Volatility of Natural Gas Price & Effect on Gas-Fired Facilities



- 25% change in natural gas price raises the steam production facility and hydrogen production cost by 17.8%



# Number of Reactors Required for Each Scenario

Type of Reactor	Number of Reactors		
	Scenario 1	Scenario 2	Scenario 3
PBMR	4	5	8
ACR-700	1	1	2
AP600	1	1	2





# Additional Nuclear-specific Assumptions

- A conservative estimate of 90% is assumed to be the learning curve for building additional reactors – some studies such as one by Westinghouse assume the learning curve to reduce costs as low as 70%
- No nuclear fuel escalation cost is assumed



# Nuclear Technology Lifetime Cost

		Lifetime Costs (\$M over 30 years)		
		PBMR	ACR-700	AP600
Scenario 1	Process Heat	829.9	1271.7	1218.8
	Electricity	1053	1053	1053
	<b>Total</b>	<b>1882.9</b>	<b>2324.7</b>	<b>2271.8</b>
Scenario 2	Process Heat	829.9	1271.7	1218.8
	Electricity	355.7	499.8	444.5
	<b>Total</b>	<b>1185.6</b>	<b>1771.5</b>	<b>1663.3</b>
Scenario 3	Process Heat	829.9	1271.7	1218.8
	Electricity	355.7	499.8	444.5
	Hydrogen    - Buy - Make	2744.2	2744.2	2744.2
		1791.7	2082.1	1983.4
	<b>Total</b>	<b>2977.3</b>	<b>3853.6</b>	<b>3646.7</b>




# Sensitivity of Total Cost to Changes in Capital Cost

	PBMR	ACR-700	AP600
Change in Total Cost for a 25% increase in Capital Cost	11.3%	13.9%	12.5%

Capital cost is an initial fixed cost, unlike natural gas cost which is a recurring cost over the lifetime, i.e. capital cost has no future volatility



# Cost Comparison of Natural Gas v. Nuclear




# Economic Conclusions

- Given current natural gas costs, nuclear is a much cheaper alternative for producing process heat for SAGD.
- Producing electricity using nuclear power is more cost-effective than buying it off the Alberta power grid or producing it using natural gas.
- While Steam-Methane Reforming has historically been a cheaper process than High Temperature Steam Electrolysis, the cost of HTSE with nuclear power is now comparable to SMR due to high natural gas cost.
- Overall, using nuclear power is a much more economically viable alternative to using natural gas due to high prices and volatility of natural gas, and new compliance regulations of the Kyoto protocol



# Reactor Licensing



# Licensing

- New application of nuclear: licensing challenge.
- CNSC: less prescriptive than the US NRC
- Requirements are site-specific.
- 3 license applications before operation:
  - license to prepare site; to construct; to operate.
- ACR-700 at an advantage in CNSC's familiarity and Canadian politics.
- Due to the less prescriptive requirements of the CNSC, it is feasible to license a new reactor design like the PBMR or the AP600.



# Canada's Disposal Plan for Nuclear Waste





# Nuclear Waste

- Intrusion Resistant Underground Structure
  - LLW, long-term, 500 year solution
- Deep geological repository
  - Spent fuel, long term disposal, to be completed in 20 yrs
- Canada will have a HLW site regardless of use of nuclear systems in oil sands



# Obstacles for Nuclear Energy Use in the Canadian Oil Sands




# Key Obstacles

- Public perception of nuclear power
  - Public education campaign required
- Constructability
- Oil Companies' Unfamiliarity with Nuclear Power
  - Have utility companies operate the nuclear power station for the oil companies
- Use of non-CANDU designs
  - Would be more costly to license, due to unfamiliarity to CNSC.
  - Would face more public/political opposition for non-Canadian design.



# Opportunities



# Constraints to Expanding Oil Sands Production with Natural gas

- Dependence on water
- Shortage of diluent
- Increasing price of natural gas
- Greenhouse gas emissions

Integration of oil sands with nuclear power addresses 3 out of 4



# Conclusion

- Large projected growth in oil sands industry
- Energy needs can be met by nuclear power
- Constraints to expanding production
- Nuclear addresses most of these concerns
- Nuclear systems can compete economically with natural gas-fired plants



# Questions?

