

Wind power planning for isolated systems *- impacts of diurnal variability*

Kiti Suomalainen

Green Islands Project

Research Integration Workshop at MIT

25-27 May 2011

Outline

- 1) Introduction to wind resource dynamics - motivation
- 2) Methodology & validation
- 3) Wind power planning for Faial and Pico
- 4) Discussion point & future work



Faial wind park.



Pico wind park.

Wind resource dynamics

Synthetic hourly wind speed data for energy systems modelling



Terceira wind park.


For..

- optimized wind power dimensioning
- surplus & shortage assessment
- storage requirements estimation
- ...

..it is critical to characterise the wind resource dynamics including..

- 1) Seasonality
- 2) Passing weather systems: day to day variability
- 3) Diurnality
- 4) Hour-to-hour variability

**Santa Maria, airport
wind speed data**



Data source: IM-DRA, 2010.

Methodology

Synthetic hourly wind speed data for energy systems modelling

1) Seasonality

Reference **daily mean** wind speed:

$$\mu_d = a_1 \sin(\omega d + \varphi) + a_2$$

2) Passing weather systems – day to day variability

Variation in daily mean wind speed (AR-model):

$$\Delta\mu_t = \omega_1 \mu_{t-1} + \omega_2 \mu_{t-2} + \dots + \omega_n \mu_{t-n} + \varepsilon$$

3) Diurnality




Reference **hourly mean** wind speed:

$$\mu_{d,h} = a_4 h^4 + a_3 h^3 + \dots + a_1$$


4) Hour-to-hour variability

Variation in hourly mean wind speed (AR-model):

$$\Delta\mu_h = \omega_1 \mu_{h-1} + \omega_2 \mu_{h-2} + \varepsilon$$



Validation




This results in a **more accurate estimation** of **resource vs. demand dynamics** from annual to hourly temporal scales.

Faial & Pico case study

Energy supply 2010

Faial



Pico





Table 1: Installed capacities.

kW	Faial	Pico
Fuel oil	22 650	16 100
Hydro	320	
Wind	1 800	1 800








Source: INESC, 2004 and EDA data, 2010

Source: EDA, 2010

Faial & Pico wind resource characteristics

Day type distribution matrices for Faial and Pico at

- Coastal,
- Mid-island and
- Offshore locations.



Offshore




Table 2: Annual mean wind speed.

m/s	Mid-island Hub height	Coastal 10m	Offshore 10m
FAIAL	7.5	5.1	7.1
PICO	10.1	3.8	7.1

Faial & Pico case study

Supply and demand scenarios

Demand:

- 1) 2010 reference case
- 2) 2018 at 1% growth rate
- 3) 2018 at 3% growth rate

Table 3: Assumed demand scenarios.


GWh	Faial	Pico	Faial & Pico
2010	54	39	93
2018 (1%)	58	43	101
2018 (3%)	64	50	118

Table 4: Applied supply side scenarios.


kW	Hydro	Wind existing	Wind mid-island	Wind coastal	Wind offshore
FAIAL	320	1800	0	0	0
			330	330	(2000)
			660	660	
			990	990	
			1980	1980	
PICO	0	1800	0	0	0
			330	330	(2000)
			660	660	
			1320	1320	
			1980	1980	
FAIAL & PICO	320	F: 1800	F: 0	F: 0	0
			990	990	2000
			1980	1980	
			3300	3300	
		P: 1800	P: 0	P: 0	
		660	660		
		1320	1320		
		3300	3300		

Methods' comparison – validation of new method


NEW
METHOD



ORIGINAL
DATA




REFERENCE
METHOD




Methods' comparison – validation of new method


NEW
METHOD



ORIGINAL
DATA




REFERENCE
METHOD




Surplus vs. renewables penetration of demand


2010



2018
1% growth rate




2018
3% growth rate




Surplus vs. renewables penetration of demand: max 6 – 4 – 10 new turbines per system


2010



2018
1% growth rate



2018
3% growth rate




Additional wind

Mid-island: 0 kW


Coastal: 0 kW

% Surplus wind vs. renewables penetration


2010



2018
1% growth rate




2018
3% growth rate




% Surplus wind vs. renewables share, 6 – 4 – 10 new turbines


2010



2018
1% growth rate




2018
3% growth rate



Hourly surplus vs. demand – by hour of day

Quantifying mean surplus wind power for additional installed wind power



Some details of the scenarios - Faial

Table 5: Selected scenarios for Faial.

Wind park	Coastal	Total kW	Fuel use Gwh	Renewable Gwh	Surplus Gwh	Renewable penetration	Wind surplus share
330	660	990	48.0	10.43	0.018	0.179	0.002
660	330		48.0	10.42	0.019	0.179	0.002
0	990		47.9	10.43	0.017	0.179	0.002
990	0		48.0	10.42	0.020	0.178	0.002
660	660	1320	46.8	11.61	0.028	0.199	0.002
330	990		46.8	11.62	0.027	0.199	0.002
990	330		46.8	11.60	0.029	0.199	0.003
660	1980	2640	42.1	16.23	0.194	0.278	0.012
1980	660		42.2	16.13	0.274	0.276	0.017
990	1980	2970	41.1	17.32	0.302	0.297	0.018
1980	990		41.2	17.21	0.393	0.295	0.023
0	3300	3300	40.0	18.36	0.470	0.314	0.025
3300	0		40.7	17.67	1.110	0.303	0.060
330	3300	3630	39.0	19.36	0.660	0.332	0.034
3300	330		39.7	18.65	1.331	0.319	0.068
1980	1980	3960	38.2	20.21	0.983	0.346	0.047
660	3300		38.1	20.31	0.905	0.348	0.043
3300	660		38.8	19.58	1.592	0.335	0.076
1980	3300	5280	34.8	23.55	2.435	0.403	0.095
3300	1980		35.4	22.97	2.997	0.393	0.117
3300	3300	6600	32.6	25.81	4.942	0.442	0.163

Some details of the scenarios - Pico

Table 6: Selected scenarios for Pico.

Wind park	Coastal	Total kW	Fuel use Gwh	Renewable Gwh	Surplus Gwh	Renewable penetration	Wind surplus share
0	660	660	31.7	11.074	0.129	0.259	0.012
660	0	660	29.8	12.924	0.343	0.302	0.026
330	330	660	30.7	12.020	0.215	0.281	0.018
330	660	990	30.0	12.721	0.262	0.298	0.020
660	330	990	29.1	13.623	0.392	0.319	0.028
0	1320	1320	30.3	12.465	0.235	0.292	0.018
1320	0	1320	26.8	15.972	0.854	0.374	0.051
660	660	1320	28.4	14.308	0.455	0.335	0.031
0	1980	1980	29.0	13.754	0.442	0.322	0.031
1980	0	1980	24.2	18.545	1.840	0.434	0.090
660	1320	1980	27.1	15.600	0.659	0.365	0.041
1320	660	1980	25.5	17.245	1.077	0.404	0.059
0	3300	3300	26.9	15.796	1.393	0.370	0.081
3300	0	3300	21.0	21.753	5.751	0.509	0.209
1320	1980	3300	23.5	19.283	2.032	0.451	0.095
1980	1320	3300	22.2	20.507	2.871	0.480	0.123
330	3300	3630	25.6	17.163	1.805	0.402	0.095
3300	330	3630	20.6	22.119	6.133	0.518	0.217
660	3300	3960	24.3	18.441	2.306	0.432	0.111
3300	660	3960	20.3	22.462	6.539	0.526	0.225
1980	1980	3960	21.5	21.251	3.623	0.497	0.146

Discussion points & future work

Discussion points

- Minimum 30% from fuel generators limit – flexible?
- Future turbine sizes & numbers?
- Surplus management strategies (turbine blades, water heating load, fly wheels,...)?
- Cost differences in the scenarios - How much surplus necessary to make EVs an interesting option?
-
-

Future work

- Specific scenarios design
- Include cost estimates
-
-

