

**REGIONAL FACTORS GOVERNING
PERFORMANCE AND
SUSTAINABILITY OF WASTEWATER
TREATMENT PLANTS IN
HONDURAS:
LAKE YOJOA SUBWATERSHED**

Katie Puckett

Kent Walker

April 22, 2011



Introduction

- Honduras
 - 2nd largest & one of poorest countries in Central America
 - Inadequate sanitation, resulting in waterborne disease
- Study site: Lake Yojoa Subwatershed
 - Largest lake in Honduras
 - Many anthropogenic sources of pollution
 - 9 municipalities, 12 microwatersheds
 - Population of about 75,000
 - Identified as a priority watershed by RAS-HON



Lake Yojoa



Water Quality in Lake Yojoa



Water Quality in Lake Yojoa



Aquatic Plant Growth



Aquatic Plant Growth



Stakeholders

- Municipality of Las Vegas
- Aquafinca
- AMPAC mine
- ENEE dam
- Agriculture
- AMUPROLAGO
- Fish restaurants (Las Casetas)
 - Where our work is focused!




Figure 4.1: Various stakeholders in and around Lake Yojoa.

State of Wastewater Treatment in Lake Yojoa Subwatershed

- Many municipalities directly discharging wastewater into local receiving water bodies
- Of those with treatment- many still discharging poor quality effluent
- Many factors
 - Lack of sufficient maintenance
 - Antiquated systems
 - Extreme hydraulic overloading
 - **Lack of money and resources**




Mayoral Meeting

- Attended mayoral meeting in Santa Barbara, Honduras
- About twenty mayors from local municipalities
- Only one of the over twenty mayors said their municipality did not have problems with wastewater treatment



Imhoff Tank

- Primary treatment wastewater system
- Two levels
 - Upper primary sedimentation
 - Lower anaerobic digester



(From Mikelonis and Hodge, 2008)



Las Vegas Imhoff Tank



Problems

- No control flow gates
- Some inflow bypasses treatment
- No way to reverse the flow



No Baffles

- Unequal flow into the two tanks
- Uneven distribution of solids
- Unequal residence times



Missing Sludge Valves

- Currently have no way to de-sludge the tanks
- Three of the six sludge valves were stolen



Lack of Maintenance



Santa Barbara Imhoff Tank



Sludge Backup



No Control Flow Gates



Missing Sludge Gates



Broken By-pass



Las Casetas

- “The little houses”:
51 fish restaurants
directly on shore of lake
- Wastewater treatment
plant built in 2008 but
never connected
- Cost approximately
\$400,000
- Focus of our work



Tilapia



Las Casetas Treatment Plant




Why Las Casetas?

- System already in place – just needs to be connected!
- Support from PRONADERS, AMUPROLAGO, and other organizations
- Provide a model for wastewater treatment in the subwatershed



Primary Tank: UASB




UASB Calculations

- Design flow: 3.18 L/s
- Peak flow: 9 L/s
- Upflow velocity:


$$V_{up} = \frac{Q}{A} = \frac{D}{\theta}$$

- COD Removal: ~80%

$$R = 100(1 - \theta^{-0.68})$$



EJE A - B - AMBAS CARAS



CORTE A PLANTA ESTRUCTURAL

ESC-1:50



UASB Calculations

Parameter	Calculated Value Under Design Flow	Calculated Value Under Peak Flow	Acceptable Value	Acceptable Under Design Flow?	Acceptable Under Peak Flow?
Reactor volume, m ³	121.04	121.04	< 1000	Yes	Yes
L:W ratio of reactor	2.6:1	2.6:1	< 4:1	Yes	Yes
Upflow velocity, m/h	0.4	1.07	< 1	Yes	No
HRT, hours	10.6	3.74	6 to 12	Yes	No




Secondary Treatment: Trickling Filter



Filter Media





ELEVACIÓN ESTRUCTURAL FILTRO PERCOLADOR

ESC-1:50




Trickling Filter: Hydraulic Loading

- Volume = 3,114 m³

- Specific area:

$$\alpha = \frac{6}{D_p} (1 - \phi)$$

- Using $D_p = 5 \text{ cm}$, $\phi = 0.25$
 - $\alpha = 90 \text{ m}^2/\text{m}^3$
 - Hydraulic loading = 0.09 m/d
 - Very low!




PLANTA ESTRUCTURAL FILTRO PERCOLADOR

ESC:1:50



Secondary Clarifier





PLANTA ESTRUCTURAL CLARIFICADOR

ESC-1:50



Recommended Overflow Rates

Sidewater depth, m	Average overflow rate, m/h	Maximum overflow rate, m/h
2	0.4	0.75
3	0.8	1.6
4	1.2	2.2
5	1.4	2.8




Calculated Overflow Rate

- Equation:

$$v_0 = \frac{Q}{A}$$

- For single clarifier, 1.6 m/h at design flow, 4.6 m/h at max flow
- Sidewater depth = 3.15 m
 - For recommended overflow rate, need both tanks!




Sludge Drying Bed



Sludge Drying Bed Area

- In general, need 0.01-0.015 m²/person
- Design population:
 - 522 permanent residents
 - + 643.5 floating population
 - = 1165.5 people total
- Total area = 30 m²
 - 0.026 m²/person!



PLANTA DE ERAS DE SECADO

ESC-1:50



Conclusions So Far

- UASB well designed
- Trickling filter may need to be reevaluated depending on results of analysis (recirculation, intermittency)
- Single secondary clarifier is not sufficient to ensure removal of suspended solids generated by filter
- Sludge drying bed is sufficient and in good shape
- Still need to:
 - Estimate BOD loading for UASB and trickling filter
 - Rework hydraulic loading calculations for trickling filter



Recommendations

- Install preliminary treatment mechanism (grit removal / screening)
- Construct another secondary clarifier tank
- Divide sludge bed into two sections
- Chlorination (included in proposal)



Major Problem



Piping Network



Piping Network



Piping Network




Distribution Tank



High Water



Construction Plans



Piping Specifications

- Plans call for coated PVC or HDPE pipe
- Instead they used black corrugated piping that sagged in the sun



Hydraulic Head

- Span of the piping system is 1.1 km
- There is 3.35 m of head to drive the flow to the distribution box
- With a constant slope of 0.305% is there enough head to drive the flow?



Head Loss Due to Friction

- Equated the head loss due to friction and other minor losses to the available head.
- Darcy-Weisbach equation

$$h_f = f \frac{L}{4R_h} \frac{V^2}{2g} = \frac{V^2}{2g} \left[\frac{fL}{4R_h} + \Sigma K \right]$$



Equate Head Loss to Available Head

$$h_f = f \frac{L V^2}{D 2g} = f \frac{L V^2}{R_h 2g}$$

$$A = f(d, D)$$


$$R_H = \frac{A}{W_p}$$

$$W_p = f(d, D)$$

$$h = LS$$


Equate

$$LS = f \frac{L V^2}{R_h 2g}$$




http://en.wikipedia.org/wiki/Circular_segment




Distance (L) =	1100	m				
Height (Z) =	3.35	m				
Slope (S) =	0.00305	ND				
Pipe Diameter (D) =	0.1524	m				
Pipe Radius (R) =	0.0762	m				
Flow (Q) =	3.18	L/s				
Q =	0.00318	m ³ /s				
Height of Water In Pipe (h) =	0.051538939	m			$h < R = 0.0762$	
Height of Water In Pipe (h) =	2.029092077	in				
d =	0.024661061	m			$d = R - h$	
θ =	2.4825	Radians			$\theta = 2 \text{ arc cos } (d/R)$	
θ =	142.23	Degrees			$\theta = 180 * \theta(\text{rad}) / \pi$	
c =	0.1442	m			$c = 2R \sin (\theta/2)$	
Arc Length (S_{arc}) =	0.1892	m			$S_{\text{arc}} = R\theta \text{ (rad)}$	
Area of Sector (A_{sector}) =	0.00721	m ²			$A_{\text{sector}} = [\theta \text{ (deg)} / 360] \pi R^2$	
Area of Triangle (A_t) =	0.00178	m ²			$A_{\text{triangle}} = 0.5cd$	
Area of the Segment (A_s) =	0.00543	m ²			$A_{\text{segment}} = A_{\text{sector}} - A_{\text{triangle}}$	
Wetted Perimeter (W_p) =	0.1892	m			$W_p = S_{\text{arc}}$	
Hydraulic Radius (R_h) =	0.0287	m			$R_h = A_{\text{segment}} / W_p$	
Velocity (v) =	0.5857	m/s			$v = Q / A_{\text{segment}}$	
*Min Velocity =	0.5	m/s		No Error		
*Max Velocity =	3	m/s		No Error		
f =	0.02					
g =	9.8	m/s ²				
$fv^2/2g \ 1/4R_h$ =	0.00305				*Used solver and set equation equal to 0.00305	

Velocity Plot



Height of Wastewater in Pipe



Conclusions

- First order analysis the piping system is a good design
- There are still some unanswered questions
 - Issues with low velocities
 - No low flow calculations
 - Possibility of solid drag due to the low flows
 - Buoyancy of distribution tank



Thank You
Questions?

